

Annual Drinking Water Quality Report for 2023
Mountain Lake Academy
386 River Road
Lake Placid, NY 12946
(Public Water Supply ID NY1505390)

INTRODUCTION

To comply with State regulations, *Mountain Lake Academy* will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system has never violated a maximum contaminant level or had any other water quality problems. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Clifford Byrne at (518) 523-4300 extension 168**. We want you to be informed about your drinking water. If you want to learn more, we would be pleased to discuss any drinking water issues in person.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants, and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately **155** people. Our water source is a 225' deep drilled well. The water is disinfected with UltraViolet units.

The NYS Dept. of Health has completed a source water assessment for this system based on available information. The source water assessment has rated this well as having an elevated susceptibility. No significant sources of contamination were identified. The well draws water from an unconfined aquifer and overlying soils are not known to provide adequate protection from potential contamination. Please note that our water supply is disinfected to ensure that the finished water delivered to **our campus** meets the New York State's drinking water standards for microbiological contamination.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Health Department (518) 891-1800.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Inorganic Contaminants							
Copper	no	2021	0.060 ¹ ND – 0.087 ²	mg/L	0	1.3 (AL)	Corrosion of household plumbing systems
Lead	no	2021	0.0013 ¹ ND – 0.0014 ²	mg/L	0	.015 (AL)	Corrosion of household plumbing systems
Nitrate	no	2023	0.27	mg/l	10	10 (MCL)	Runoff from fertilizer use; Leaching from septic tanks, sewage; erosion of natural deposits.
Sodium	no	2022	2.1	mg/l	n/a	See note 3	Naturally occurring; Road salt; Water softeners; Animal waste.

Notes:

¹ The level presented represents the 90th percentile of the 5 sites tested. The 90th percentile is equal to or greater than 90% of the copper and lead values detected in your water system.

² The levels represent the range of lead and copper samples collected in your system. The action level for copper and lead was not exceeded at any of the 5 sites tested.

³ Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): Picocuries per liter is a measure of the radioactivity in water

EPA Test Method 533 is used to measure PFOA and PFOS which are regulated perfluoroalkyl analytes with an MCL level of 10 nanograms per liter (ng/L) or 10 parts of liquid per 1 trillion parts of liquid. As part of EPA Test Method 533 a total of 25 analytes are also measured as part of that test. Unregulated perfluoroalkyl analytes that were analyzed in our water samples and had detectable levels are shown in the Unregulated Perfluoroalkyl Substances table provided below.

Unregulated Perfluoroalkyl Substances					
MCL level for each Unregulated PFAS Substance = 50,000 ng/L					
Contaminant	Violation (Yes/No)	Date of Sample	Level Detected	Unit Measurement	MCGL or Health Advisory Level ^{1,2}
Perfluorooctane Sulfonic Acid 6:2 FTS	No	2023	1.93	ng/L	NA

¹ USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available.

² All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 50,000 ng/L.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. We are required to include the following information on lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from

materials and components associated with service lines and home plumbing. Mountain Lake Academy is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Clifford Byrne at (518) 523-4300 extension 168. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

Last year our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions.

You can play a role in conserving water by becoming conscious of the amount of water being **used on campus**, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide you with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

Summary of Lead Service Line Inventory

I. System Information

Water System Name	Mountain Lake Academy
PWS ID Number	NY1505390

II. Contact Information for Owner / Licensed Operator of Record Completing the Form

Contact Name	Clifford Byrne
Contact Phone Number	518-523-4300 x 168
Contact Email Address	cbyrne@mountainlakeacademy.org

III. Summary of Inventory

Total Number of Service Lines in the Distribution System	3
Total Number of Identified Service Lines	3
Total Number of Lead Service Lines	0
Total Number of GSLRR	0
Total Number of Non-LSL	3
Total Number of Unknown Service Lines	0

Service Lines	Lead	GSL or GSLRR	Non-Lead	Unknown
PWS - Side Service Lines	0	0 GSL	3	0
Customer - Side Service Lines	0	0 GSL	3	0
Total Number of Service Lines in the Distribution System	0	0 GSLRR	3	0

Service Line Identification Methods

Identification Methods	PWS- Side SLs	Customer-Side SLs
Historical Records	0	0
Field Inspection	3	3
Customer Identification with Photo or other Verification	NA	0
Excavation	0	0
Sequential Sampling	0	0
Statistical Analysis/Predictive Model	0	0

IV. Inventory Availability - The inventory must be available to public

<p>If 50,000 customers or greater: Posting the inventory online water system's website.</p> <p>If under 50,000 customers: Explain how to access the inventory</p>	<p>Address:</p> <p style="text-align: center;">Website</p>
---	--

V. Certifications

<p><i>By submitting this form, I have verified and certify the information listed in this form is true and accurate to the best of my knowledge and belief.</i></p>		
Cliff Byrne	Quality Assurance, Licensed Water Operator Officer	10/9/2024
Name	Title	Date

Water System Field Compliance Inspection Summary Report

Operation: MOUNTAIN LAKE ACADEMY WS #3 SCHOOL BLDG (ID: 1079442)
Facility Name: MOUNTAIN LAKE ACADEMY
Facility Code: 15-AB76 Facility Email: cmariano@mountainlakeacademy.org;mverni@mo
Facility Address: 386 River Road, Lake Placid, NY 12946
NYS Public Water Supply (PWS) ID: NY1505390

To the Attention of:

Chris Mariano
MOUNTAIN LAKE ACADEMY
386 River Road
Lake Placid, NY 12946
Email: cmariano@mountainlakeacademy.org

Sanitary Survey

Date: October 9, 2024 11:00 AM
Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)
Responsible Person: Cliff Byrne
Additional Email(s): cbyrne@mountainlakeacademy.org

Summary

Number of Critical Violations Found: 0
Number of Other Violations Found: 0
Number of Deficiencies Found: 0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO CRITICAL VIOLATIONS REPORTED

NO NON-CRITICAL VIOLATIONS REPORTED

NO DEFICIENCIES REPORTED

Water System Information


Source Type: Ground,
Type of Disinfection: UV Light
Disinfection Waiver Issued? No
4-Log Treatment Installed? No
Coliform Surveillance Sample Collected? Yes
1) Time: 11:00 AM Location: Staff BCWT

UV Intensity Reading(s):

1) UV Intensity: 100%

Water System Notes:

Comments: No issues noted.



Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)



Received by: Cliff Byrne

Water System Field Compliance Inspection Summary Report

Operation: MOUNTAIN LAKE ACADEMY WS #2 BROOKVIEW (ID: 1079441)
Facility Name: MOUNTAIN LAKE ACADEMY
Facility Code: 15-AB76 Facility Email: cmariano@mountainlakeacademy.org;mverni@mo
Facility Address: 386 River Road, Lake Placid, NY 12946
NYS Public Water Supply (PWS) ID: NY1505390

To the Attention of:

Chris Mariano
MOUNTAIN LAKE ACADEMY
386 River Road
Lake Placid, NY 12946
Email: cmariano@mountainlakeacademy.org

Sanitary Survey

Date: October 9, 2024 10:30 AM
Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)
Responsible Person: Cliff Byrne
Additional Email(s): cbyrne@mountainlakeacademy.org

Summary

Number of Critical Violations Found: 0
Number of Other Violations Found: 0
Number of Deficiencies Found: 0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO CRITICAL VIOLATIONS REPORTED

NO NON-CRITICAL VIOLATIONS REPORTED

NO DEFICIENCIES REPORTED

Water System Information

Source Type: Ground,
Type of Disinfection: UV Light
Disinfection Waiver Issued? No
4-Log Treatment Installed? No
Coliform Surveillance Sample Collected? Yes
1) Time: 10:45 AM Location: Health Office Sink

UV Intensity Reading(s):

1) UV Intensity: 100%


Water System Notes:

Comments: No issues noted.

Operator indicated that there are periods of low flow/pressure when the system is under peak demand conditions. The 6 GPM flow restrictor for the small Sterillie UV unit installed is likely the cause.



Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)



Received by: Cliff Byrne

Water System Field Compliance Inspection Summary Report

Operation: MOUNTAIN LAKE ACADEMY WS #1 MAIN BLDG (ID: 358804)
Facility Name: MOUNTAIN LAKE ACADEMY
Facility Code: 15-AB76 Facility Email: cmariano@mountainlakeacademy.org;mverni@mo
Facility Address: 386 River Road, Lake Placid, NY 12946
NYS Public Water Supply (PWS) ID: NY1505390

To the Attention of:

Chris Mariano
MOUNTAIN LAKE ACADEMY
386 River Road
Lake Placid, NY 12946
Email: cmariano@mountainlakeacademy.org

Sanitary Survey

Date: October 9, 2024 10:00 AM
Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)
Responsible Person: Cliff Byrne
Additional Email(s): cbyrne@mountainlakeacademy.org

Summary

Number of Critical Violations Found: 0
Number of Other Violations Found: 0
Number of Deficiencies Found: 0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO CRITICAL VIOLATIONS REPORTED

NO NON-CRITICAL VIOLATIONS REPORTED

NO DEFICIENCIES REPORTED

Water System Information

Source Type: Ground,
Type of Disinfection: UV Light
Disinfection Waiver Issued? No
4-Log Treatment Installed? No
Coliform Surveillance Sample Collected? Yes
1) Time: 11:30 AM Location: Laundry utility sink

UV Intensity Reading(s):


1) UV Intensity: 81%
2) UV Intensity: 100%

Water System Notes: Surveillance sample was taken after the two other systems were inspected when inspector returned to main building to assist with lead service line inventory 11:30-11:45 AM.

Comments: No issues noted.



Inspector: Amanda Lavigne (amanda.lavigne@health.ny.gov)



Received by: Cliff Byrne